

SUPPLEMENT TO ATTACHMENT D - ALLOCATION METHODOLOGY

Amended as of January 25, 2021

RENEWABLE WATER RESOURCES

LOCAL LIMITATIONS

Purpose:

Local limitations have been determined in accordance with Section 4.3 - National Categorical Pretreatment Standards or Local Limitations and Attachment D - Allocation Methodology. The specific limitations for the POTW's requiring Local Limitations are as follows:

POTW:

**NPDES NO.
POLLUTANT
OF CONCERN**

	DURBIN	GILDER	LOWER	MAULDIN
	CREEK	CREEK	REEDY	ROAD
	SC0040002	SC0040525	SC0024261	SC0041211
	MONTHLY AVG.	MONTHLY AVG.	MONTHLY AVG.	MONTHLY AVG.
	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>
ANTIMONY	0.5	1.5	1.0	2.0
ARSENIC	--	0.8	0.2	0.2
CADMIUM	0.5	0.1	0.5	0.4
T. CHROMIUM	1.5	1.5	1.5	3.0
COPPER	1.2	1.5	1.5	2.0
CYANIDE	0.4	0.5	0.2	0.4
LEAD	0.5	0.5	0.2	0.5
MERCURY	0.0017	0.002	0.0053	0.012
NICKEL	1.0	2.5	1.5	4.0
SILVER	0.1	0.1	0.2	0.08
THALLIUM	0.037	--	--	--
ZINC	1.5	3.0	1.5	4.0

POTW:

**NPDES NO.
POLLUTANT
OF CONCERN**

	GEORGES	PELHAM	PIEDMONT	SLATER-
	CREEK	ROAD	REGIONAL	MARIETTA*
	SC0047309	SC0033804	SC0048470	SC0026883
	MONTHLY AVG.	MONTHLY AVG.	MONTHLY AVG.	MONTHLY AVG.
	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>
ANTIMONY	2.0	0.5	1.0	--
ARSENIC	0.5	0.4	0.5	--
CADMIUM	0.4	0.5	0.5	--
T. CHROMIUM	2.0	1.5	1.5	--
COPPER	0.5	1.5	1.5	--
CYANIDE	0.4	0.4	0.4	--
LEAD	0.5	0.4	0.5	--
MERCURY	0.025	0.0008	0.025	--
NICKEL	2.0	1.5	1.5	--
SILVER	0.2	0.5	0.5	--
ZINC	2.0	1.5	1.5	--

NOTE: Limitations for all facilities:

- Grease And Oil; HEM - 200 mg/l
- Polar Material - 200 mg/l
- Non-polar Material - 100 mg/l
- pH: 6.0-10.0 su