ATTACHMENT E

SEWER USE REGULATION SELF-MONITORING FREQUENCY (Effective May 20, 2019)

All Users subject to self-monitoring requirements shall sample at a minimum as indicated in the following monitoring schedule. The self-monitoring frequency will be based upon total permitted flow. However, ReWa may modify the sampling frequency based on factors including compliance history and risk to ReWa WRRF facilities and products.

Total Permitted Flow Gallons per Day	Frequency of Monitoring
0 - 1,000	Semi-annually
1,001 - 10,000	Quarterly
10,001 - 50,000	Twice Quarterly
50,001 - 100,000	Monthly
100,001 - 500,000	Twice Monthly
Over 500,000	Weekly