

ATTACHMENT E

RENEWABLE WATER RESOURCES

SELF MONITORING INTERVAL

All Industrial Users subject to monitoring requirements shall sample at a minimum as indicated in the following monitoring schedule. A different sampling interval may be required of an industrial discharger as a result of a more frequent sampling scheduling, a categorical standard or if the Director requires different sampling because of the impact of the discharger on the receiving wastewater treatment plant. The Director may also reduce the sampling scheduling, at his discretion, after taking into consideration such factors as the Industrial Users compliance status and pollution prevention activities.

Total Process Flow Gallons/Day	Frequency of Monitoring
0 - 1,000	Semi annually
1,001 - 10,000	Quarterly
10,001 - 50,000	Twice/Quarter
50,001 - 100,000	Monthly
100,001 - 500,000	Twice/Monthly
Over 500,000	Weekly

The permitted flow will be the indicator of the frequency of monitoring. When applicable and where feasible, flow proportioned composite samples shall be utilized to document and evaluate compliance with this Regulation.