

**SUPPLEMENT TO ATTACHMENT D - ALLOCATION METHODOLOGY**

**Amended as of May 23, 2016**

**RENEWABLE WATER RESOURCES**

**LOCAL LIMITATIONS**

Purpose:

Local limitations have been determined in accordance with Section 4.3 - National Categorical Pretreatment Standards or Local Limitations and Attachment D - Allocation Methodology. The specific limitations for the POTW's requiring Local Limitations are as follows:

POTW:	DURBIN CREEK SC0040002	GILDER CREEK SC0040525	LOWER REEDY SC0024261	MAULDIN ROAD SC0041211
NPDES NO.	DAILY AVG.	DAILY AVG.	DAILY AVG.	DAILY AVG.
POLLUTANT OF CONCERN	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>
BOD5	800	800	800	800
TSS	700	700	700	700
ANTIMONY	0.5	1.5	1.0	2.0
ARSENIC	*	1.5	0.2	0.2
CADMIUM	0.5	0.1	0.5	0.4
T. CHROMIUM	1.5	1.5	1.5	3.0
COPPER	1.2	1.5	1.5	2.0
CYANIDE	0.4	0.5	0.2	0.4
LEAD	0.5	0.5	0.2	0.5
MERCURY	0.0017	0.002	0.0053	0.012
NICKEL	1.0	3.0	1.5	4.0
SILVER	0.1	0.1	0.2	0.08
ZINC	1.5	3.0	1.5	4.0
1,2,4-TRICHLOROBENZENE BIS (2-ETHYLHEXYL)	*	*	*	*
PHTHALATE	*	*	*	*

POTW:	GEORGES CREEK SC0047309	PELHAM ROAD SC0033804	PIEDMONT REGIONAL SC0048470	SLATER- MARIETTA SC0026883
NPDES NO.	DAILY AVG.	DAILY AVG.	DAILY AVG.	DAILY AVG.
POLLUTANT OF CONCERN	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>	<u>LIMIT (mg/l)</u>
BOD5	800	800	800	*
TSS	700	700	700	*
ANTIMONY	2.0	0.5	1.0	*
ARSENIC	0.5	*	0.5	*
CADMIUM	0.4	0.5	0.5	*
T. CHROMIUM	2.0	1.5	1.5	*
COPPER	0.5	1.5	1.5	*
CYANIDE	0.4	0.4	0.4	*
LEAD	0.5	0.4	0.5	*
MERCURY	0.025	0.0008	0.025	*
NICKEL	2.0	1.5	1.5	*
SILVER	0.2	0.5	0.5	*
ZINC	2.0	1.5	1.5	*
1,2,4-TRICHLOROBENZENE BIS (2-ETHYLHEXYL)	*	*	*	*
PHTHALATE	*	*	*	*

\* To be determined pending modifications to Headworks Analysis and SCDHEC approval. 1988 approved limitations remain in effect during interim period.

NOTE: Limitations for all facilities:

- Grease - 200 mg/l
- And Oil - 100 mg/l
- pH: 6.0-10.0 su
- COD: 3 X BOD