

Addendum II FY18 Gravity Sewer and Manhole Rehabilitation Project

Posting Date: April 23, 2018

In published Request for Bid (RFB) for FY18 Sewer Rehab project, please note the following updates:

1. **Q:** To perform the CCTV inspections, contractor must cut protruding taps and complete point repairs. There's no bid item for point repairs, can the reference to point repairs (Pg. 226) be removed?
A: No changes will be made to the specifications. Bid Item #4 covers service lateral point repairs.
2. **Q:** Tensile strength 3000 psi – can this be removed? Tensile strength is only applicable to pressure pipe only per ASTM F1216?
A: The tensile strength requirements for the various diameters and depths will remain as stated in the specifications.

If you have any questions and/or concerns, please do not hesitate to contact Julie Dacus at julied@re-wa.org or Stephanie Selman stephanies@re-wa.org.