

Addendum I Lower Reedy WRRF Digester Capacity Improvements Project

Posting Date: January 10, 2019

In published Request for Bid (RFB) for Facilities Improvements IDC project, please note the following updates:

1. **Q:** Can you provide contact information at Greenville County for permits?
A: Greenville County Building Permit No. 18-9490 and contact is Dean Miles 864-467-4915
2. **Q:** Can you provide information on linear mixer by Ovivo?
A: See Specification Section 11480 attached and attached C.1 Reference Document – Linear Motion Mixer Proposal.
3. **Q:** Specification Section 07185 Traffic-Bearing Waterproofing is called for @ the Preliminary Treatment Facility which is not at this project as there is NO Preliminary Treatment Facility...Please confirm.
A: See Item No. 8 of this addendum.
4. **Q:** Wall pipes listed in spec section 2.02 on page 15000-3 list non-standard wall collar sizes which will be additional charge due to being made to order. Will you allow standard wall collars?
A: Yes, standard wall collars are allowed.
5. **Q:** Spec section 2.04 on page 15000-4 call for MJ solid sleeves to be C110. All other MJ fittings are allowed to be C153 compact. Will you allow C153 compact MJ sleeves?
A: C153 Compact MJ sleeves are not allowed.
6. **Q:** Bolts for DI flange joints are called out as A307. Will 304SS or 316SS bolts be required for submerged flanged bolts?
A: No.
7. The final shop drawing for the Varec Waste Gas Flare and the Ovivo Linear Motion Mixer will be included by addendum once finalized.
8. Specification Section 07185: Paragraph 1.01.B.1, Delete this sentence and replace with “Install waterproofing at Control Building No. 2 as shown on the Drawings (Lower roof areas not directly above electrical room).”

9. Specification Section 11070: Add the attached Section 11070 – Contractor Installation of Owner-Furnished Equipment.
10. Specification Section 11480: Add the attached Section 11480 – Linear Motion Mixers.
11. Specification Section 11486: Add the attached Section 11486 – Digester Gas Safety and Control Equipment.
12. C.1 Reference Document – Add the attached C.1 Reference Document – Linear Motion Mixer Proposal at the end of Section 00311.
13. Drawing R100 – Add the attached Drawing R100 – Reference Drawing of NPW PS for demolition activities.

If you have any questions and/or concerns, please do not hesitate to contact Stephanie Selman stephanies@re-wa.org or Julie Dacus at julied@re-wa.org.