

Addendum III Mauldin Road WRRF Metal Storage Building Project

Posting Date: February 25, 2019

In published Request for Bid (RFB) for Metal Storage Building project, please note the following updates:

1. **Q:** Where is the electrical for the building being fed from? Distance/building/direction? Would you prefer us to quote stubbing out 5 feet from the building and determining the tie-in at a later time?

A: ReWa shall supply and install a disconnect for Contractor to tie power into.

If you have any questions and/or concerns, please do not hesitate to contact Stephanie Selman stephanies@re-wa.org or Julie Dacus at julied@re-wa.org.